




Republic of the Philippines
GOVERNMENT ARSENAL
Camp General Antonio Luna
Limay, Bataan
Telefax: 421 1554 / (047) 244 5624
E-mail address: arsenaldnd@yahoo.com

GA BIDS AND AWARDS COMMITTEE
Supplemental Bulletin Nr GA-BAC-IP-20-01
Procurement of Infrastructure Projects
GA-BAC-2020-IP-01
30 January 2020

1. This is to inform all prospective bidders for the Re-Roofing of Machine Shop under Lot I of GA-BAC-2020-IP-01 for the clarifications on the Technical Specifications of the project.
2. Tabulated below are the queries raised by prospective bidder/s with the corresponding clarifications/response thereto, to wit:

Item No.	Queries	Clarifications
1	Turn buckle location	The location of turn buckle is at the uppermost topcord of the first truss down to the lower bottomcord of the second truss, arranged based on the roof framing plan
2	CHB thickness and size	The thickness of wall is 150 mm (5" CHB used with 1/2" plaster finished, both sides)
3	Roof drain plumbing	Not included
4	C-purlin & Hardie Senepa size	Using 2" x 4" x 1.20 mm & 2" x 6" x 1.20 mm C-purlin with 12" x 10 mm Hardie Senepa (See Detail B, S-2)
5	Truss details	Please check roof framing plan (S-3) for comparison
6	Truss vertical support design	Using 2 x 2 x 1/4 angle bar with 2 x 2 x 3/16 angle bearing seat
7	Wall location due for replacement	See revision cloud (A-2)
8	Painting application	Two coating
9	Wall color (exterior and interior)	As per existing color of building
10	Tolerance on thickness of roofing	.38 mm to .40 mm

3. Please be guided accordingly.


MS. TERESITA L. VITUG
Chairperson, Bids & Awards Committee